საქართველოს სტანდარტი

დაცვა ელვისგან - ნაწილი 1: ზოგადი პრინციპები

საქართველოს სტანდარტებისა და მეტროლოგიის ეროვნული სააგენტო თბილისი

საინფორმაციო მონაცემები

1 შემუშავებულია საქართველოს სტანდარტების და მეტროლოგიის ეროვნული სააგენტოს სტანდარტების დეპარტამენტის მიერ

2 დამტკიცებულია და შემოღებულია სამოქმედოდ საქართველოს სტანდარტების და მეტროლოგიის ეროვნული სააგენტოს 2019 წლის 30 სექტემბრის № 68 განკარგულებით

3 მიღებულია გარეკანის თარგმნის მეთოდით საერთაშორისო ელექტროტექნიკური კომისიის სტანდარტი იეკ 62305-1:2010 "დაცვა ელვისგან - ნაწილი 1: ზოგადი პრინციპები"

4 პირველად

5 რეგისტრირებულია საქართველოს სტანდარტების და მეტროლოგიის ეროვნული სააგენტოს რეესტრში: 2019 წლის 30 სექტემბერი №268-1.3-015244

დაუშვებელია წინამდებარე სტანდარტის სრული ან ნაწილობრივი კვლავწარმოება, ტირაჟირება და გავრცელება სსიპ საქართველოს სტანდარტებისა და მეტროლოგიის ეროვნული სააგენტოს ნებართვის გარეშე





Edition 2.0 2010-12

INTERNATIONAL STANDARD

Protection against lightning – Part 1: General principles





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office 3, rue de Varembé CH-1211 Geneva 20 Switzerland Email: inmail@iec.ch Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Catalogue of IEC publications: <u>www.iec.ch/searchpub</u>

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

IEC Just Published: <u>www.iec.ch/online_news/justpub</u>

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

Electropedia: <u>www.electropedia.org</u>

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

Customer Service Centre: <u>www.iec.ch/webstore/custserv</u>

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: <u>csc@iec.ch</u> Tel.: +41 22 919 02 11 Fax: +41 22 919 03 00





Edition 2.0 2010-12

INTERNATIONAL STANDARD

Protection against lightning – Part 1: General principles

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ICS 29.020; 91.120.40

ISBN 978-2-88912-280-6

CONTENTS

FO	REWORD	5
INT	roduction	7
1	Scope	8
2	Normative references	8
3	Terms and definitions	8
4	Lightning current parameters	14
5	Damage due to lightning	14
	5.1 Damage to a structure	14
	5.1.1 Effects of lightning on a structure	14
	5.1.2 Sources and types of damage to a structure	16
	5.2 Types of loss	16
6	Need and economic justification for lightning protection	18
	6.1 Need for lightning protection	18
_	6.2 Economic justification of lightning protection	19
7	Protection measures	19
	7.1 General	19
	7.2 Protection measures to reduce injury of living beings by electric shock	19
	7.3 Protection measures to reduce physical damage	20
	7.4 Protection measures selection	20
8	Basic criteria for protection of structures	20
Ŭ	8.1 General	21
	8.2 Lightning protection levels (LPL)	21
	8.3 Lightning protection zones (LPZ)	23
	8.4 Protection of structures	25
	8.4.1 Protection to reduce physical damage and life hazard	25
	8.4.2 Protection to reduce the failure of internal systems	26
Anı	nex A (informative) Parameters of lightning current	27
Anı	nex B (informative) Time functions of the lightning current for analysis purposes	38
Anı	nex C (informative) Simulation of the lightning current for test purposes	44
Anı	nex D (informative) Test parameters simulating the effects of lightning on LPS	
cor	nponents	48
Anı	nex E (informative) Surges due to lightning at different installation points	62
Bib	liography	67
Fig	ure 1 – Connection between the various parts of IEC 62305	7
Fig dar	ure 2 – Types of loss and corresponding risks resulting from different types of mage	18
Fig	ure 3 – LPZ defined by an LPS (IEC 62305-3)	24
Fig	ure 4 – LPZ defined by an SPM (IEC 62305-4)	25
Fig	Jure A.1 – Definitions of impulse current parameters (typically T_2 2 ms)	27
Fia	ure A.2 – Definitions of long duration stroke parameters (typically 2 ms 7 one	
1	s)	28

Figure A.3 – Possible components of downward flashes (typical in flat territory and to lower structures)
Figure A.4 – Possible components of upward flashes (typical to exposed and/or higher structures)
Figure A.5 – Cumulative frequency distribution of lightning current parameters (lines through 95 % and 5 % value)
Figure B.1 – Shape of the current rise of the first positive impulse
Figure B.2 – Shape of the current tail of the first positive impulse
Figure B.3 – Shape of the current rise of the first negative impulse
Figure B.4 – Shape of the current tail of the first negative impulse
Figure B.5 – Shape of the current rise of the subsequent negative impulses
Figure B.6 – Shape of the current tail of the subsequent negative impulses
Figure B.7 – Amplitude density of the lightning current according to LPL I
Figure C.1 – Example test generator for the simulation of the specific energy of the first positive impulse and the charge of the long stroke
Figure C.2 – Definition of the current steepness in accordance with Table C.3
Figure C.3 – Example test generator for the simulation of the front steepness of the first positive impulse for large test items
Figure C.4 – Example test generator for the simulation of the front steepness of the subsequent negative impulses for large test items
Figure D.1 – General arrangement of two conductors for the calculation of electrodynamic force
Figure D.2 – Typical conductor arrangement in an LPS55
Figure D.3 – Diagram of the stresses <i>F</i> for the configuration of Figure D.255
Figure D.4 – Force per unit length F' along the horizontal conductor of Figure D.2
Table 1 – Effects of lightning on typical structures
Table 2 – Damage and loss relevant to a structure according to different points ofstrike of lightning17
Table 3 – Maximum values of lightning parameters according to LPL
Table 4 – Minimum values of lightning parameters and related rolling sphere radiuscorresponding to LPL22
Table 5 – Probabilities for the limits of the lightning current parameters
Table A.1 – Tabulated values of lightning current parameters taken from CIGRE(Electra No. 41 or No. 69) [3], [4]
Table A.2 – Logarithmic normal distribution of lightning current parameters – Mean μ and dispersion σ_{log} calculated from 95 % and 5 % values from CIGRE (Electra No. 41 or No. 69) [3], [4]
Table A.3 – Values of probability <i>P</i> as function of the lightning current <i>I</i>
Table B.1 – Parameters for Equation (B.1)
Table C.1 – Test parameters of the first positive impulse
Table C.2 – Test parameters of the long stroke
Table C.3 – Test parameters of the impulses
Table D.1 – Summary of the lightning threat parameters to be considered in the calculation of the test values for the different LPS components and for the different LPL49
Table D.2 – Physical characteristics of typical materials used in LPS components

Table D.3 – Temperature rise for conductors of different sections as a function of W/R	52
Table E.1 – Conventional earthing impedance values Z and Z_1 according to the resistivity of the soil	63
Table E.2 – Expected surge overcurrents due to lightning flashes on low-voltage systems	64
Table E.3 – Expected surge overcurrents due to lightning flashes on telecommunication systems	65

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PROTECTION AGAINST LIGHTNING –

Part 1: General principles

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62305-1 has been prepared by IEC technical committee 81: Lightning protection.

This second edition cancels and replaces the first edition, published in 2006, and constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- 1) It no longer covers protection of services connected to structures.
- 2) Isolated interfaces are introduced as protection measures to reduce failure of electric and electronic systems.
- 3) First negative impulse current is introduced as a new lightning parameter for calculation purposes.
- 4) Expected surge overcurrents due to lightning flashes have been more accurately specified for low voltage power systems and for telecommunication systems.