

საქართველოს სტანდარტი

ბენზინის შემავსებელი სადგურები - ნაწილი 3: წანაცვლებითი სარქველების
მოწყობისათვის უსაფრთხოების მოთხოვნები

საქართველოს სტანდარტებისა და მეტროლოგიის
ეროვნული სააგენტო
თბილისი

საინფორმაციო მონაცემები

1 დამტკიცებულია და შემოღებულია სამოქმედოდ საქართველოს სტანდარტებისა და მეტროლოგიის ეროვნული სააგენტოს 2015 წლის 27 მარტის № 21 და 2015 წლის 10 თებერვლის № 9 განკარგულებებით

2 მიღებულია გარეკანის თარგმნის მეთოდით სტანდარტიზაციის ევროპული კომიტეტის სტანდარტი ენ 13617-3:2012 „ბენზინის შემავსებელი სადგურები - ნაწილი 3: წანაცვლებითი სარქველების მოწყობისათვის უსაფრთხოების მოთხოვნები“

3 პირველად

4 რეგისტრირებულია საქართველოს სტანდარტებისა და მეტროლოგიის ეროვნული სააგენტოს რეესტრში: 2015 წლის 27 მარტი №268-1.3-6979

აკრძალულია ამ სტანდარტის გადაცემა მესამე პირებისათვის ან/და მისი სხვა ფორმით
გავრცელება

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 13617-3

March 2012

ICS 75.200

Supersedes EN 13617-3:2004

English Version

Petrol filling stations - Part 3: Safety requirements for
construction and performance of shear valves

Stations-service - Partie 3: Exigences de sécurité relatives
à la construction et aux performances des raccords de
sécurité

Tankstellen - Teil 3: Sicherheitstechnische Anforderungen
an Bau- und Arbeitsweise von Abscherventilen

This European Standard was approved by CEN on 28 January 2012.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

	Page
Foreword	3
Introduction	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	5
4 Explosion protection measures	6
5 Construction	6
5.1 General requirements	6
5.2 Specific requirements	7
5.3 Classes of construction	7
5.4 Threads	7
6 Physical properties	7
7 Operational requirements	8
8 Tests	8
8.1 General	8
8.2 Type tests	8
8.3 Production acceptance tests	8
8.4 Routine tests	9
9 Information for use	9
9.1 General	9
9.2 Marking and instruction	9
Annex A (normative) Instructions — Guide for items to be included in manufacturers' installation and user manual	11
Annex B (normative) Test methods	12
B.1 General requirements	12
B.2 Pressure test (routine test)	12
B.3 Main valve test (routine test)	12
B.4 Pressure relief valve test (routine test)	12
B.5 Fuel preconditioning (type test)	13
B.6 Pressure test (type test)	13
B.7 Main valve test (type test)	13
B.8 Check valve test (class I only) (type test)	13
B.9 Pressure relief valve test (class I only) (type test)	14
B.10 Thermal link test 1 (class I and class II only) (type test and production acceptance test)	14
B.11 Thermal link test 2 (class I and class II only) (type test and production acceptance test)	14
B.12 Main valve closure test (type test and production acceptance test)	14
B.13 Main valve closure test (type test and production acceptance test)	15
Annex C (informative) Environmental aspects	16
Annex ZA (informative) Relationship between this European Standard and the Essential Requirements of EU Directive 94/9/EC	18

Foreword

This document (EN 13617-3:2012) has been prepared by Technical Committee CEN/TC 393 "Equipment for tanks and filling stations", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2012, and conflicting national standards shall be withdrawn at the latest by September 2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 13617-3:2004.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this document.

According to edition EN 13617-3:2004 the following fundamental changes are given:

- a new note at the end of the scope: 'Fuels other than of Explosion Group IIA are excluded from this European Standard' added;
- informative Annex C concerning environmental aspects added.

The present standard is composed of the following parts:

- *Part 1: Safety requirements for construction and performance of metering pumps, dispensers and remote pumping units;*
- *Part 2: Safety requirements for construction and performance of safe breaks for use on metering pumps and dispensers;*
- *Part 3: Safety requirements for construction and performance of shear valves;*
- *Part 4: Safety requirements for construction and performance of swivels for use on metering pumps and dispensers.*

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

The function of the shear valve is to prevent continuous liquid or vapour release in the event of impact or fire

საინფორმაციო ნაწილი. სრული გელექტრონული დოკუმენტი მდგრადად დაგენერირდება მიზანის მიხედვით.