

## საქართველოს სტანდარტი

დაბალი ძაბვის გამანაწილებელი და მარეგულირებელი მოწყობილობა-  
ნაწილი 5-5: წრედის მართვის მოწყობილობა და ჩამრთველი ელემენტები  
ავარიული გაჩერების ხელსაწყო ჩამკეტი ფუნქციის მექანიზმით  
(იეკ 60947-5-5:1997/A1:2005)

საქართველოს სტანდარტებისა და მეტროლოგიის  
ეროვნული სააგენტო  
თბილისი

**სსტ ენ 60947-5-5:1997/A1:2005/2019**

**საინფორმაციო მონაცემები**

**1 შემუშავებულია საქართველოს სტანდარტების და მეტროლოგიის ეროვნული სააგენტოს სტანდარტების დეპარტამენტის მიერ**

**2 დამტკიცებულია და შემოღებულია სამოქმედოდ საქართველოს სტანდარტების და მეტროლოგიის ეროვნული სააგენტოს 2019 წლის 6 დეკემბრის № 98 განკარგულებით**

**3 მიღებულია გარეკანის თარგმნის მეთოდით სტანდარტიზაციის ევროპული კომიტეტის სტანდარტი ენ 60947-5-5:1997/A1:2005 „დაბალი ძაბვის გამანაწილებელი და მარეგულირებელი მოწყობილობა-ნაწილი 5-5: წრედის მართვის მოწყობილობა და ჩამრთველი ელემენტები ავარიული გაჩერების ხელსაწყო ჩამკეტი ფუნქციის მექანიზმით (იეკ 60947-5-5:1997/A1:2005)”**

**4 პირველად**

**5 რეგისტრირებულია საქართველოს სტანდარტების და მეტროლოგიის ეროვნული სააგენტოს რეესტრში: 2019 წლის 6 დეკემბერი №268-1.3-016512**

**დაუშვებელია წინამდებარე სტანდარტის სრული ან ნაწილობრივი კვლავწარმოება, ტირაჟირება და გავრცელება სსიპ საქართველოს სტანდარტებისა და მეტროლოგიის ეროვნული სააგენტოს ნებართვის გარეშე**

EUROPEAN STANDARD

EN 60947-5-5/A1

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2005

ICS 29.130.20 ; 29.120.99

English version

**Low-voltage switchgear and controlgear  
Part 5-5: Control circuit devices and switching elements –  
Electrical emergency stop device with mechanical latching function  
(IEC 60947-5-5:1997/A1:2005)**

Appareillage à basse tension  
Partie 5-5: Appareils et éléments de  
commutation pour circuits de commande -  
Appareil d'arrêt d'urgence électrique  
à accrochage mécanique  
(CEI 60947-5-5:1997/A1:2005)

Niederspannungsschaltgeräte  
Teil 5-5: Steuergeräte und Schaltelemente -  
Elektrisches NOT-AUS-Gerät  
mit mechanischer Verrastfunktion  
(IEC 60947-5-5:1997/A1:2005)

This amendment A1 modifies the European Standard EN 60947-5-5:1997; it was approved by CENELEC on 2005-03-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This amendment exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Central Secretariat: rue de Stassart 35, B - 1050 Brussels**

## Foreword

The text of document 17B/1389/FDIS, future amendment 1 to IEC 60947-5-5:1997, prepared by SC 17B, Low-voltage switchgear and controlgear, of IEC TC 17, Switchgear and controlgear, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as amendment A1 to EN 60947-5-5:1997 on 2005-03-01.

The following dates were fixed:

- latest date by which the amendment has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2005-12-01
- latest date by which the national standards conflicting with the amendment have to be withdrawn (dow) 2008-03-01

Annex ZA has been added by CENELEC.

---

## Endorsement notice

The text of amendment 1:2005 to the International Standard IEC 60947-5-5:1997 was approved by CENELEC as an amendment to the European Standard without any modification.

---

**Replace annex ZA of EN 60947-5-5:1997 by:**

### **Annex ZA (normative)**

#### **Normative references to international publications with their corresponding European publications**

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

**NOTE** Where an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-441	1984	International Electrotechnical Vocabulary (IEV) Chapter 441: Switchgear, controlgear and fuses	-	-
A1	2000		-	-
IEC 60068-2-1	1990	Environmental testing Part 2: Tests - Tests A: Cold	EN 60068-2-1	1993
A1	1993		A1	1993
A2	1994		A2	1994
IEC 60068-2-2	1974	Part 2: Tests - Tests B: Dry heat	EN 60068-2-2	1993
A1	1993		A1	1993
A2	1994		A2	1994
IEC 60068-2-6 + corr. March	1995 1995	Part 2: Tests - Test Fc: Vibration (sinusoidal)	EN 60068-2-6	1995
IEC 60068-2-11	1981	Part 2: Tests - Test Ka: Salt mist	EN 60068-2-11	1999
IEC 60068-2-27	1987	Part 2: Tests - Test Ea and guidance: Shock	EN 60068-2-27	1993
IEC 60068-2-30 + A1	1980 1985	Part 2: Tests - Test Db and guidance: Damp heat, cyclic (12 + 12-hour cycle)	EN 60068-2-30	1999
IEC 60073	2002	Basic and safety principles for man-machine interface, marking and identification - Coding principles for indicators and actuators	EN 60073	2002
IEC 60204-1	1997	Safety of machinery - Electrical equipment of machines Part 1: General requirements	EN 60204-1 + corr. September	1997 1998
A1	1999		-	-

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60721-3-3	1994	Classification of environmental conditions Part 3: Classification of groups of environmental parameters and their severities -- Section 3: Stationary use at weatherprotected locations	EN 60721-3-3	1995
A1	1995		-	-
A2	1996		A2	1997
IEC 60947-1	2004	Low-voltage switchgear and controlgear Part 1: General rules	EN 60947-1 + corr. November	2004 2004
IEC 60947-5-1	2003	Part 5-1: Control circuit devices and switching elements - Electromechanical control circuit devices	EN 60947-5-1 + corr. November	2004 2004
IEC 61310-1	1995	Safety of machinery - Indication, marking and actuation Part 1: Requirements for visual, auditory and tactile signals	EN 61310-1	1995
ISO 3864	1984	Safety colours and safety signs	-	-
ISO 13850	1996	Safety of machinery - Emergency stop - Principles for design	-	-

NORME  
INTERNATIONALE  
INTERNATIONAL  
STANDARD

CEI  
IEC

60947-5-5

1997-11

AMENDEMENT 1  
AMENDMENT 1  
2005-01

---

---

---

Amendment 1

**Appareillage à basse tension –**

**Partie 5-5:**

**Appareils et éléments de commutation  
pour circuits de commande –  
Appareil d'arrêt d'urgence électrique  
à accrochage mécanique**

Amendment 1

**Low-voltage switchgear and controlgear –**

**Part 5-5:**

**Control circuit devices and switching elements –  
Electrical emergency stop device  
with mechanical latching function**

© IEC 2005 Droits de reproduction réservés — Copyright - all rights reserved

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland  
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: [inmail@iec.ch](mailto:inmail@iec.ch) Web: [www.iec.ch](http://www.iec.ch)

---

---



Commission Electrotechnique Internationale  
International Electrotechnical Commission  
Международная Электротехническая Комиссия

CODE PRIX  
PRICE CODE

J

*Pour prix, voir catalogue en vigueur  
For price, see current catalogue*

## AVANT-PROPOS

Le présent amendement a été établi par le sous-comité 17B: Appareillage à basse tension, du comité d'études 17 de la CEI: Appareillage.

Le texte de cet amendement est issu des documents suivants:

FDIS	Rapport de vote
17B/1389/FDIS	17B/1399/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cet amendement.

Le comité a décidé que le contenu de cet amendement et de la publication de base ne sera pas modifié avant la date de maintenance indiquée sur le site web de la CEI sous "http://webstore.iec.ch" dans les données relatives à la publication recherchée. A cette date, la publication sera

- reconduite,
- supprimée,
- remplacée par une édition révisée, ou
- amendée.

Le contenu du corrigendum de juillet 2007 a été pris en considération dans cet exemplaire.

---

Page 2

## SOMMAIRE

*Modifier le titre de 7.7 comme suit:*

7.7 Essais de verrouillage, de réarmement et de choc

*Ajouter, sous Figure 1, ce qui suit:*

Tableau 1 – Robustesse d'un organe de commande à bouton

Tableau 2 – Relation entre le trou de montage de l'arrêt d'urgence et la hauteur du marteau

*Supprimer ce qui suit:*

Annexe A – Manœuvre d'urgence

Page 4

## AVANT-PROPOS

*Supprimer la phrase relative à l'Annexe A.*

*Remplacer le dernier alinéa par ce qui suit:*

La présente norme doit être utilisée conjointement avec la CEI 60947-1 et la CEI 60947-5-1.

## FOREWORD

This amendment has been prepared by subcommittee 17B: Low-voltage switchgear and controlgear, of IEC technical committee 17: Switchgear and controlgear.

The text of this amendment is based on the following documents:

FDIS	Report on voting
17B/1389/FDIS	17B/1399/RVD

Full information on the voting for the approval of this amendment can be found in the report on voting indicated in the above table.

The committee has decided that the contents of this amendment and the base publication will remain unchanged until the maintenance result date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
  - withdrawn,
  - replaced by a revised edition, or
  - amended.
- 

Page 3

## CONTENTS

*Modify the title of 7.7 as follows:*

7.7 Latching, resetting and impact tests

*Add, under Figure 1, the following:*

Table 1 – Robustness of a button type actuator

Table 2 – Relationship between the emergency stop mounting hole and the hammer height

*Delete the following:*

Annex A – Emergency operation

Page 5

## FOREWORD

*Delete the sentence concerning Annex A.*

*Replace the last paragraph by the following:*

This standard should be used in conjunction with IEC 60947-1 and IEC 60947-5-1.