

საქართველოს სტანდარტი

სსკ: 13.310

გამაფრთხილებელი სიგნალის სისტემები - შეჭრისა და თავდასხმის სისტემები
- გამოყენების სახელმძღვანელოები

საინფორმაციო მონაცემები

1. მიღებულია და დაშვებულია სამოქმედოდ: სსიპ-საქართველოს სტანდარტებისა და მეტროლოგიის ეროვნული სააგენტოს გენერალური დირექტორის 30/12/2020 წლის № 125 განკარგულებით

2. მიღებულია „თავფურცლის“ თარგმნის მეთოდით: სტანდარტიზაციის ევროპული კომიტეტის (სენ) სტანდარტი სლს/ტს 50131-7:2010 „გამაფრთხილებელი სიგნალის სისტემები - შეჭრისა და თავდასხმის სისტემები - გამოყენების სახელმძღვანელოები“

3. პირველად

4. რეგისტრირებულია: სსიპ-საქართველოს სტანდარტებისა და მეტროლოგიის ეროვნული სააგენტოს რეესტრში 30/12/2020 წლის №268-1.3-019566

წინამდებარე სტანდარტის ნებისმიერი ფორმით გავრცელება სააგენტოს ნებართვის გარეშე აკრძალულია

English version

**Alarm systems -
Intrusion and hold-up systems -
Part 7: Application guidelines**

Systemes d'alarme -
Systemes d'alarme contre l'intrusion
et les hold-up -
Partie 7: Guide d'application

Alarmanlagen -
Einbruch- und Überfallmeldeanlagen -
Teil 7: Anwendungsregeln

This Technical Specification was approved by CENELEC on 2010-06-25.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

This Technical Specification was prepared by the Technical Committee CENELEC TC 79, Alarm systems. It was circulated for vote in accordance with the Internal Regulations, Part 2, Subclause 11.3.3.3 and was approved by CENELEC as CLC/TS 50131-7 on 2010-06-25

This document supersedes CLC/TS 50131-7:2008.

Compared to the previous edition the changes are the following:

- 3.1.46: note deleted;
- 10.2: “the test signals replaced with “these signals” in the last paragraph;
- 10.4: “hold-up triggering devices” replaced with “hold-up devices” in the 2nd paragraph;
- Annex B, B.6: “Psychological problems of persons after robbery” deleted;
- Annex D, D.13: “avoid” replaced with “minimize”.

The following date was fixed:

- latest date by which the existence of the CLC/TS
has to be announced at national level (doa) 2011-01-01

The EN/TS 50131 series consists of the following parts, under the general title *Alarm systems – Intrusion and hold-up systems*:

Part 1	System requirements
Part 2-2	Intrusion detectors – Passive infrared detectors
Part 2-3	Requirements for microwave detectors
Part 2-4	Requirements for combined passive infrared and microwave detectors
Part 2-5	Requirements for combined passive infrared and ultrasonic detectors
Part 2-6	Opening contacts (magnetic)
Part 2-7-1	Intrusion detectors – Glass break detectors (acoustics)
Part 2-7-2	Intrusion detectors – Glass break detectors (passive)
Part 2-7-3	Intrusion detectors – Glass break detectors (active)
Part 2-8 ¹⁾	Intrusion detectors – Vibration detectors
Part 2-9 ¹⁾	Intrusion detectors – Active infrared detectors
Part 3	Control and indicating equipment
Part 4	Warning devices
Part 5-1 ¹⁾	Requirements for wired interconnection for I&HAS equipments located in supervised premises
Part 5-3	Requirements for interconnections equipment using radio frequency techniques
Part 6	Power supplies
Part 7	Application guidelines
Part 8	Security fog device/systems
Part 9 ¹⁾	Alarm verification – Methods and principles

¹⁾ At draft stage.

Contents

Introduction	5
1 Scope	7
2 Normative references	7
3 Terms, definitions and abbreviations	7
3.1 Terms and definitions	7
3.2 Abbreviations	12
4 Security grade of I&HAS	12
4.1 Security grading	12
5 Environmental classification	13
5.1 Environmental Class I – Indoor.....	13
5.2 Environmental Class II – Indoor – General	13
5.3 Environmental Class III – Outdoor – Sheltered or indoor extreme conditions	13
5.4 Environmental Class IV – Outdoor – General.....	13
6 General	14
6.1 Other components	14
6.2 Electrical safety.....	14
6.3 Unwanted alarms	14
6.4 Responsibility.....	14
6.5 Qualifications	14
6.6 Competence.....	14
6.7 Tools.....	14
6.8 Confidentiality	14
6.9 Consultation	14
6.10 Compatibility	15
7 System design	15
7.1 Location survey – Risk	15
7.2 Location survey – Other influences.....	16
7.3 System design proposal	16
8 Installation planning	21
8.1 General.....	21
9 System installation	22
9.1 Installation process	22
10 Inspection, functional testing and commissioning	22
10.1 Inspection	22
10.2 Functional testing.....	22
10.3 Commissioning.....	22
10.4 Handover	22
10.5 Test period.....	23
10.6 Acceptance	23
10.7 As-fitted document	23
10.8 Certificate of conformance.....	23
11 Documentation and records	24
11.1 Documentation	24
11.2 Records	24
12 Operation of I&HAS	25

13 Maintenance and repair of I&HAS	25
13.1 General	25
13.2 Inspection and servicing	25
13.3 Repair	26
Annex A (normative) Special national conditions	27
Annex B (informative) System design – Location survey – Contents	28
Annex C (informative) Systems design – Location survey – Building	29
Annex D (informative) Location survey – Influences affecting I&HAS originating within the supervised premises	31
Annex E (informative) Location survey – Influences affecting I&HAS originating outside the supervised premises	34
Annex F (informative) Levels of supervision	36
Annex G (normative) Information to be included in the system design proposal	37
Annex H (informative) Technical survey	39
Annex I (informative) System record (log book)	51
Annex J (informative) Maintenance	52
Annex K (informative) Flow chart	53
Bibliography	54
Table	
Table F.1 – Levels of supervision	36
Figure	
Figure K.1 – Flow chart	53

Introduction

These application guidelines are intended to provide advice relating to the design, installation, operation and maintenance of Intruder and Hold-up Alarm Systems (I&HAS). The purpose of this document is to ensure, as far as is practical, that I&HAS provide the required performance with a minimum of unwanted alarms.

These application guidelines are set out in the logical order in which an I&HAS would normally be designed and installed. Each procedure is set out separately in the guideline but it is accepted that, in practice, some of the procedures may be carried out simultaneously. Annex K describes in the form of a flowchart the main processes and documentation included in this application guideline.

Those responsible for the design, installation planning, system installation, commissioning, operation and maintenance of I&HAS should be conversant with other European Standards relating to I&HAS, particularly those relating to system performance, control and indicating equipment, detectors, warning devices, power supplies and alarm transmission systems.

These application guidelines are set out in seven main clauses; a brief explanation of each section is shown below.

i) Clause 7 – System design

This clause is intended to assist those responsible for designing I&HAS to design I&HAS suitable for the premises to be supervised in relation to the perceived risk(s). The design of I&HAS will depend on many factors all of which will influence more or less the design of I&HAS. Consideration of these factors will result in a system design proposal for an I&HAS with the appropriate extent, security grade and environmental class.

ii) Clause 8 – Installation planning

This clause is intended to help those responsible for installing I&HAS by highlighting issues which should be considered prior to commencing the installation of the I&HAS.

iii) Clause 9 – System installation

In this clause, guidance is given with regard to issues arising during the installation of I&HAS. This clause is intended to ensure I&HAS is correctly installed as specified at the design stage.

iv) Clause 10 – Inspection, functional testing and commissioning

In this clause, guidance is given on issues arising after I&HAS has been installed. The clause is intended to ensure I&HAS has been installed as specified and also provides the level of performance intended at the design stage. Guidance is also provided with regard to the proper commissioning and handing over of the system to the user and to the documents, records and operating instructions which should be provided.

v) Clause 11 – Documentation and records

This clause describes the documentation which should be provided to the client on completion of I&HAS. The documents are intended to provide a history of modifications to I&HAS, based on the as-fitted document, prepared when I&HAS installation was completed.

The records are intended to chronicle any corrective action carried out following unwanted alarm conditions and details of any repairs or modifications to I&HAS. The record should also include details of temporary fault conditions.

საინფორმაციო ნაწილი. სრული ტექსტის სახანაგად შეიძინეთ სტანდარტი.

vi) Clause 12 – Operation of I&HAS

This clause describes the responsibility of the client or user of I&HAS to properly maintain I&HAS and to ensure it is operated correctly.

vii) Clause 13 – Maintenance and repair of I&HAS

This clause describes how I&HAS should be maintained and repaired to ensure I&HAS continues to provide the level of performance intended at the design stage.

საინფორმაციო ნაწილი. სრული ტექსტის სანახავად შეიძინეთ სტანდარტი.